

ROUND DUCT

SPECIFICATION

Fabrication standard: DW 144 | ASHRAE

Material: G.I | Aluminium | Black Steel | Stainless Steel

Assembly: Pre-Assembly or Full Assembly

Application: HVAC | Ventilation | Kitchen Hood | Other



ORDER SIZE

- RO: D x d - H

EXAMPLE ORDER SIZE

- RO:D150 x d150 - H150

HANGER DIMENSION & RECOMMEND SHEET STEEL THICKNESS

Dimension of duct Width size	G.I Metal thickness (mm)	Steel rod (mm)	Steel Hanger (mm)	Spacingduct (mm)
Up to 600	0.6	8	V-30x30x3	1800
600 to 800	0.8	10	V-40x40x4	1800
850 to 1000	0.8	12	V-50x50x5	1500
1050 to 1800	1	14	U-100x50x5	1500
1850 to 2400	1.2	16	U-100x50x5	1500
2400 to 3000	1.2	18	U-100x50x5	1500

If no standard required, Fast will fabricate air duct follow SMACNA standard. HVAC duct construction standard metal and flexible, Second Edition - 1995

