



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Diameter, mm	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
EN 10255 Medium ^{a, d, g, h, j, m, p}	China	DN15, DN20, DN25, DN32, DN40, DN50	175	1205	FM Approved
EN 10255 Medium ^{a, d, h, m, p}	China	DN25, DN32, DN40, DN50, DN65, DN80, DN100, DN125, DN150	300	2070	FM Approved

Notes:

- a - FM Approved for use with FM Approved pipe couplings on rolled grooves
- d - When hot dip galvanized by factory, the sprinkler pipe is FM Approved for dry pipe systems
- g - FM Approved for use with plain-end fittings
- h - FM Approved for use when the listings of the couplings or fittings make specific mention of their suitability with this sprinkler pipe.
- j - 1/2 in (DN15) and 3/4 in (DN20) nominal size limited for use in valve trim
- m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe
- p - Manufactured out of EN 10255 Grade S195T steel

Designed & Manufactured at: Jinan Mech Piping Technology Co Ltd, Meigui Zone of Industrial Park, Pingyin, Jinan City, Shandong Province, China

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3058870

Approval Granted: June 29, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA