

CERTIFICATE OF COMPLIANCE

Certificate Number 20141128-EX26550
Report Reference EX26550-20141128
Issue Date 2014-NOVEMBER-28

Issued to: JINAN MECH PIPING TECHNOLOGY CO LTD
MEIGUI ZONE OF INDUSTRIAL PARK
PINGYIN ,SHANDONG 250400 CHINA

This is to certify that
representative samples of

METALLIC SPRINKLER PIPE

Schedule 40 steel sprinkler pipe in the 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6 and 8 in sizes, as per ASTM A53/A53M-07, Grade B, Type E.
Schedule 10 steel sprinkler pipe in the 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6 and 8 in sizes, as per ASTM A795-13, Grade B, Type E.


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852 - Standard for Metallic Sprinkler Pipe For Fire Protection
ULC/ORD C199S - Standard for Light Wall Steel Pipes for Sprinkler
Systems for Fire Protection Service

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

